

上川総合振興局公宅消防用設備保守点検業務 設備一覧

		旭川市																				富良野市										士別市				美深町				数量計					
		単位	旭川市	大雪町	97共14号A P	98共15号A P	99共16号A P	2000共17号 A P	2001共18号 A P	2001共19号 A P	93共11号A P	95共12号A P	96共13号A P	99共2号A P	90共3号A P	91共9号A P	2002共永山 1号A P	2002共永山 2号A P	2002共永山 3号A P	2003共永山 4号A P	2003共永山 5号A P	東光A	東光B	東光C	東光D	専光台農勝 公宅	計	97富井結木 A P	98富井新富 A P	99富井花園 A P	2000富井園 町A P	2001富井幸 日A P	計	95士井西4 条A P	2001士井東 2条A P	計	2001美深共 西1条1号A P	2001美深共 西1条2号A P	計						
機器点検及び総合点検（1回目）																																													
(1)	消火器具																																												
	粉末消火器（新圧式） 新設・引取【一次物流費】	本	12	11	8	8	8	8	8	12								9	9	6	6	9	4	4	4	4		130	6	4	2	6	2	20								150			
(2)	粉末消火器（加圧式）	本																																											
	粉末消火器（蓄圧式）	本																									4	4									6	2	8	2	2	4		16	
	自動火災報知設備																																												
	受信機P型1級（19回線以下）	面		1	2	2	1	1	1	1																		9	2					2							11				
	受信機P型2級	面	1																									1														1			
	副受信機（19回線以下）	面						1	1	1	2																	5													5				
	差動式ｽﾎﾟｯﾄ型感知器（50個まで）	個	46	50	50	50	50	50	50	50	50																	396	50				50								446				
	差動式ｽﾎﾟｯﾄ型感知器（51個から100個まで）	個				50	50	48	48	48	50																	294	36				36								330				
	差動式ｽﾎﾟｯﾄ型感知器（101個以上）	個				14	14				39																	67													67				
	定温式ｽﾎﾟｯﾄ型感知器（50個まで）	個	47	50	50	50	50	50	50	50	50																	397	50			50									447				
	定温式ｽﾎﾟｯﾄ型感知器（51個から100個まで）	個		1	46	47	31	15	15	50	50																	205	23				23								228				
	定温式ｽﾎﾟｯﾄ型感知器（101個以上）	個								5																		5														5			
	定温式ｽﾎﾟｯﾄ型感知器（防爆形）	個																																											
	煙感知器（50個まで）	個	11	10	3	3	3	2	2	3																			37	2			2									39			
	表示灯	灯	3	4		8	8	8	8	12																			51													51			
	P型1線発信機	個		4		8	8	8	8	12																			48													48			
	P型2線発信機	個	3																										3													3			
	音響装置	個	3	4	8	8	8	8	8	12																			59	6			6								65				
常用電源	組	1	1	2	2	1	1	1	1																			10	2			2									12				
予備電源（受信機のみ）	組	1	1	2	2	1	1	1	1																			10	2			2									12				
(3)	避難器具																																												
	はしご（建築物の地上階数2 ロープ又は金属）	組			2	2			1	1	1	4	3	3	3	3	2	3									2	27	2	4	1		7	3		3						37			
	はしご（建築物の地上階数3 ロープ又は金属）	組			2	2			1	1	1	4	3	3	3	3	2	3										25	2				2	3		3						30			
	はしご（建築物の地上階数4）	組			2	2			1	1	1	4	3	3	3	3	2	3										25														25			
(4)	漏電火災警報装置																																												
	電源	組	2	2																								4														4			
	受信機	面	2	2																								4													4				
	音響装置	組	2	2																								4													4				
	変流器	組	2	2																								4													4				
	漏洩電流検出状況及び音響装置	組	2	2																								4													4				
(5)	排煙設備																																												
	制御盤（10回線以下）	面	1	1																								2														2			
	防火戸（ドア式S型 50枚まで）	枚	6	6																								12														12			
	防火戸（ドア式W型 50枚まで）	枚																																											
	可動垂れ壁（50連まで）	連																																											
	垂直降下式垂れ壁	枚																																											
	受信機P型1級（19回線以下）	面																																											
	煙感知器（50個まで）	個	6	6																									12													12			
	音響装置	個																																											
	常用電源	組																																											
	予備電源（受信機のみ）	組																																											
(6)	配線	棟	1	1	1	1	1	1	1	1																		8	1					1								9			
絶縁抵抗測定及び配線点検※建物単位																																													
		単位	旭川市																								富良野市										士別市				美深町				数量計
			旭川市	大雪町	97共14号A P	98共15号A P	99共16号A P	2000共17号 A P	2001共18号 A P	2001共19号 A P	93共11号A P	95共12号A P	96共13号A P	99共2号A P	90共3号A P	91共9号A P	2002共永山 1号A P	2002共永山 2号A P	2002共永山 3号A P	2003共永山 4号A P	2003共永山 5号A P	東光A	東光B	東光C	東光D	専光台農勝 公宅	計	97富井結木 A P	98富井新富 A P	99富井花園 A P	2000富井園 町A P	2001富井幸 日A P	計	95士井西4 条A P	2001士井東 2条A P	計	2001士井東 2条A P	2001士井東 2条A P	計						
1	機器点検（2回目）																																												